Combustible Dust: Food That Goes Boom By Merrill Childs



Cargill - Éddyville, Iowa

Iowa-Illinois Safety Council Coralville, IA April 12, 2018





- Food and Agriculture Products
- Based in Minneapolis
- > Starches, Sweeteners & Texturizers NA
 - Corn Starch
 - Animal Feed
 - Sweeteners
- Fermentation productsOther Businesses



Contact Information

Feel free to contact me with any questions

Merrill Childs Cargill - Eddyville, IA 641-969-3626 merrill_childs@cargill.com

Disclaimer

The information in this presentation are my opinions only. Verify for yourself any information before you use it. I am not liable for any use of this content.

Product brand names are examples only







Combustible Dust

- Merrill's Objectives
 - Protect people from dust explosions
 - Protect property from dust explosions
 - Regulatory Compliance
 - Appropriate level of control



Agenda

- Why common dust explodes
- History of dust explosions
- OSHA ???????????
- NFPA Combustible Dust standards
- Combustible dust properties (Kst, Pmax, MIE)
- Dust Explosion Prevention
- Explosion venting
- Explosion suppression
- Explosion isolation
- Housekeeping and flash fires
- Demonstration of small dust explosion























Sample	Sample of Data		
Product	K _{st}	P _{max} (bar)	MIE (mJ)
Sugar	138	8.5	400-700
Corn Starch	143-202	7.8-10.3	30-300
Coal Dust	152	8.3	60-700
Corn	75/169	9.4/7.8	40
Gluten Meal	116	7.3	50-100
Feed/Bran	67-120	7.3-8.3	300-500
Soy Flour	117	7.4	>500
Wheat Flour	87	8.3	60
Cocoa	62-108	6.5-9.1	120
Cottonseed Hulls	46	7.4	>500
Cellulose	82	8.6	1000-10,000
Citric Acid	100	6.8	> 400,000
Glucosamine	105	10.2	>28,000
Erythritol	255	7.2	4

Why So Dangerous?

- Dust Explosions produce
 Flame ball over 30 feet long in controlled venting
- Pressure from air heating up rapidly can be over 150 psig if pressure is contained
- Both occur in less than 100 milliseconds
- Equipment or enclosures are not rated for the peak pressure that is generated in about 100msec can catastrophically fail resulting in personnel injury and significant property damage.



Cedar Rapids, Iowa

On May 22, 1919, the Douglas Starch Works exploded at about 6:30 p.m. There were 109 men in the plant at the time of the explosion. The pillar of dust and flames shot skyward about 5000 feet and the explosion was felt 30 miles away. Doors were blown open and windows shattered at the Cedar Rapids Country Club three and one-half miles away.

Of the 43 men who lost their lives, 10 bodies were never found, 10 bodies were partially found and buried in a common grave in Linwood Cemetery.



DeBruce Elevator Explosion

June 8, 1998 near Wichita, Kansas
11 people were injured, and seven died

This dust explosion appeared to propagate through almost the entire complex, both in the tunnels below, and the structures across the top of the silos. Almost no part of the elevator was untouched by the explosion. Many of the silos had their tops blown out. A prime example of the force of the explosion was a heavy steel door which covered one of the tunnel entrances, approximately 7 feet by 7 feet, weighing about 600–800 pounds, which was missing. Initially rescue workers wondered where it had gone, until someone looked up...and saw that it appeared to be "shrink-wrapped" into the I beams of the gallery floor 120 feet straight up!



DeBruce Elevator Explosion

- June 8, 1998 near Wichita, Kansas
- > 11 people were injured, and seven died

This dust explosion appeared to propagate through almost the entire complex, both in the tunnels below, and the structures across the top of the silos. Almost no part of the elevator was untouched by the explosion. Many of the silos had their tops blown out. A prime example of the force of the explosion was a heavy steel door which covered one of the tunnel entrances, approximately 7 feet by 7 feet, weighing about 600–800 pounds, which was missing. Initially rescue workers wondered where it had gone, until someone looked up...and saw that it appeared to be "shrink-wrapped" into the I beams of the gallery floor 120 feet straight up!

























Simmons Poultry Feed Mill -12/1/15

- Fairland, OK
- Fire smoldered for weeks
- Explosion blew top off silo
- 3 people seriously burned 5 years ago from an explosion and fire







Hinton IA Grain Elevator

- Central Valley Ag elevator
- March 17, 2016
- Explosion and fire
- Dump control house in flames
- > 2 people severely burned



WestPine MDFB

- Quesnel, BC
- March 9, 2016
- > Explosion and fire involve 4 baghouses
- Facility had demonstrated it had a compliant program for management of combustible wood dust



Oregano Explosion

- April 5, 2016
- ▶ Spice plant in Reno, NV
- Dust explosion in grinding hopper
- No injuries



Emsland-Stärke (Germany)

- June 7, 2016
- Explosion when workers opened inspection hatch of a mixing machine for corn starch
- ▶ 1 fatality



<section-header><list-item><list-item><list-item><list-item><list-item><table-row>

Fate & Lyle September 26, 2016 Francesville, Indiana Explosion started in bucket elevator leg 2 people severely injured and later died













Regulatory: OSHA

- OSHA 1910-272 Grain Standard Dec 31, 1987
 Held up as an effective model
- OSHA developing a new standard
- NEP (National Emphasis Program) Oct 2007 & March 2008
- \circ Enforcement by using the General Duty Clause
- OSHA process delayed GHS (Globally Harmonized System) March 2012
- $\,\circ\,$ Dust included as a "Hazardous Chemical"
- The CSB (Chemical Safety Board) designated general dust standard as first <u>"Most Wanted Safety Improvement</u>."





NFPA Dust Standards

- Consensus Standards
- Guidance for Prevention and Mitigation
- ► RAGAGEP (Recognized And Generally Accepted Good Engineering Practices)
- Great resource
- Not Directly Enforceable by OSHA
 General Duty Clause





NFPA Occupancy Standards NFPA 652: Fundamentals of Combustible Dust New September 7, 2015 Industry Specific NFPA 61: Agriculture and Food Processing NFPA 484: Combustible Metals NFPA 484: Combustible Metals NFPA 655: Sulfur NFPA 664: Wood Processing and Woodworking NFPA 654: Combustible Particulate Solids

Industry Specific Standard Prevails

NFPA 68: Deflagration Venting NFPA 69: Explosion Prevention Systems NFPA 77: Static Electricity NFPA 91: Air Conveying NFPA 499: Classification of Hazardous Locations NFPA 70: NEC (National Electrical Code) NFPA 13: Sprinkler Systems

- NFPA 15: Water Spray for Fire Protection
- NFPA 72: Fire Alarm and Signaling



NFPA: DHA (Dust Hazard Analysis)

- > Evaluate fire, deflagration, and explosion hazards
- Specific fire and deflagration scenarios
 - ID safe operating ranges
 - ID safeguards in place
- Recommendation of additional safeguards to manage the hazards
- Performed or led by a qualified person
- Documented including action items



DHA Techniques

- Checklist Analysis
- What If Analysis
- What If with Checklist
- HAZOP (Hazard and Operability Analysis)
- LOPA (Layers of Protection Analysis)
- > FEMA (Failure Modes and Effects Analysis)



NFPA 652: DHA Retroactivity For existing processes undergoing material modification (25% of original cost), DHAs as part of the project

 For other existing processes complete DHAs within a 3 5-year period and demonstrate reasonable progress in each of the 3 years

NOTE: Originally 5 years





NFPA 652: Management of Change

Written procedures to manage changes to:

- Process materials
- Technology and equipment
- Procedures and facilities
- Staffing
- Job tasks



NFPA: Housekeeping

- Included in all NFPA Occupancy Standards
- Housekeeping strategy
- Accumulation depths



FM Global 5-1 Elect Equip in Hazardous Locations 5-8 Static Electricity 7-17 Explosion Protection Systems 7-73 Dust Collectors and Collection Systems 7-75 Grain Storage and Milling 7-76 Prevention and Mitigation of Combustible Dust Explosion & Fire







Ignition Prevention System

- No Smoking on site
- Management of Hot Work
- Welding
- Cutting
- Grinding



Ignition Prevention Magnets to remove tramp metal Bonding and Grounding Bearing Temperature Monitoring Belt alignment switches (rub blocks) Belt slow down switch Electrical Classifications Class II, Div 1, Group G Dust usually present Rated enclosures Class II, Div 2, Group G Dust not usually present Dust tight enclosures

































Explosion Protection

- Containment 10 bar (150 psi) construction
- Explosion Relief Venting
- Explosion Suppression
- Explosion Isolation

























Venting Considerations

- Environment
- Operating Conditions
- Vessel Location
- Vessel Strength
- Interconnections;
 Isolate ducting
- Post Explosion Fires
- Reaction Forces
- Line of Fire





Fireball Size				
Vessel size (cubic ft)	Fireball with 1 vent (ft)	Vents	Fireball (ft)	
10	17	1	17	
50	30	2	23	
100	37	3	26	
500	63	4	40	
			K	













Flameless Vents

Designed for applications where equipment is indoors & safe venting through ducting is not possible or flameball is not acceptable.











 1 Yes
 1 No

 1 Yes
 1 No





















































Contact Information

Feel free to contact me with any questions

Merrill Childs Cargill - Eddyville, IA 641-969-3626 <u>merrill_childs@cargill.com</u>

